

DEHS-Test according to DIN EN 14644-3

PARMESS

MAM Cleanroom Measurement



In the following, all times are shown in local time with the corresponding UTC offset.

Print date: 10. Apr 2025 (Europe/Berlin (UTC +2:00))

Page 1 of 3

Protocol sheet - Repeated measurement no. 1

Building: MKLTST Room: MKLTST_R02 Equipment No.: Testequipment
Measurement point: MP-Filter01 Filter class: H14
Measure. point group: Demo MPG Filter Scan-/Leaktest
Description: Demo measurement point group for showcasing scan- and leaktests
Start measuring: 10. Apr 2025

Measuring device used:

Particle measuring device	Name	Flow	Next calibration
Raw air	SIM-SEQ1	472.000 [cm ³ /s]	30. Dec 2050
Clean air	SIM-SEQ2	472.000 [cm ³ /s]	30. Dec 2050

Differential pressure measuring device	Next calibration
DPMD01	02. Apr 2029

Dilution stage	Dilution factor	Next calibration
DS271	100	01. Apr 2026

Probe	Measuring notebook
Probe09	VMWIN11MOQLERO

Filter test measurement results

Filter type	Visual Inspection OK	Differential pressure [Pa]			Scan / Leak test ok
		Actual	Max.	Result	
supply air filter	ok	50.0	500.0	ok	ok

Overall result	R	includes the result(s) of the repeated measurement(s)
-----------------------	----------	---

Measured by: **John, Doe (jdoe)**

Participants: n.d. n.d.

DEHS-Test according to DIN EN 14644-3

PARMESS

MAM Cleanroom Measurement



In the following, all times are shown in local time with the corresponding UTC offset.

Print date: 10. Apr 2025 (Europe/Berlin (UTC +2:00))

Page 2 of 3

Protocol sheet - Repeated measurement no. 1

Building: MKLTST Room: MKLTST_R02 Equipment No.: Testequipment
Measurement point: MP-Filter01 Filter class: H14
Measure. point group: Demo MPG Filter Scan-/Leaktest
Description: Demo measurement point group for showcasing scan- and leaktests
Start measuring: 10. Apr 2025

Signature for: Filter No.: MP-Filter01

Login: **tadmin** Name: **Tom Administrator**

Date: **10. Apr 2025** Comment: **Following the resolution of the filter malfunction, the system has been reverified and is now fully suitable for production use.**
16:05:01

Test Print

DEHS-Test according to DIN EN 14644-3

PARMESS

MAM Cleanroom Measurement



In the following, all times are shown in local time with the corresponding UTC offset.

Print date: 10. Apr 2025 (Europe/Berlin (UTC +2:00))

Page 3 of 3

Protocol sheet - Repeated measurement no. 1

Building: MKLTST Room: MKLTST_R02 Equipment No.: Testequipment
Measurement point: MP-Filter01 Filter class: H14
Measure. point group: Demo MPG Filter Scan-/Leaktest
Description: Demo measurement point group for showcasing scan- and leaktests
Start measuring: 10. Apr 2025

Dynamic measurement

Probe geometry:

Effective width [cm]: 2.55
Height [cm]: n.d.
Diameter [cm]: 3.60

Parameter scantest

Scan velocity [cm/s]: 8.0
Track overlap [cm]: 1.0
 N_a [1]: 0
 N_p [1]: 4
 P_L [%]: 0.01
Flow raw air [m³/s]: 0.00047200
Minimum raw air concentration [1/m³]: 266,915,788
Scan time calculated [min]: 4

Evaluation scantest

Number of possible leaks: 0

Measurement results dynamic measurement

No.	Raw air				Clean air			Penetration rate [%]
	Start measuring	Measurement duration [s]	Particle $\geq 0.3\mu\text{m}$ [1/m ³]	Requirements fulfilled *	Start measuring	Measurement duration [s]	Particle $\geq 0.3\mu\text{m}$	
1	10. Apr 2025 15:25:40+02:00	60	310,192,400	Yes	10. Apr 2025 15:25:39+02:00	60	1,208	0.00039
2	10. Apr 2025 15:26:12+02:00	60	322,073,500	Yes	10. Apr 2025 15:25:58+02:00	60	913	0.00028
3	10. Apr 2025 15:26:52+02:00	60	318,720,100	Yes	10. Apr 2025 15:26:31+02:00	60	642	0.00020
4	10. Apr 2025 15:27:03+02:00	60	316,255,300	Yes	10. Apr 2025 15:26:41+02:00	60	804	0.00025
Summary		240	n.d.	Yes	n.d.	240	n.d.	n.d.

* Particle concentration $\geq 0.3\mu\text{m}$ [1/m³] > Minimum raw air concentration [1/m³]